

Perignano, 02/07/2013

**Subject : Sound pressure level measurement of pumps**

The maximum sound pressure level, emitted by the machine, was measured with the Machinery Directive 89/927/CEE, 93/44/CEE and 93/68/CEE as described in the attachment I comma f of regulations.

Tests were performed with not submerged pump.

The values expressed in dB (A) are summarized in Table 1

<b>MODEL</b>	<b>dB(A)</b>
<b>X-AJE 80 P</b>	66
<b>X-AJE 120</b>	65
<b>X-AMO 100</b>	55
<b>X-AMO 120 B</b>	57
<b>X-AMV 150</b>	62

**Table 1**

Ing. Simone Palmeri  
Steelpumps technical manager  
tecnico@steelpumps.it

**STEELPUMPS s.r.l.**

SEDE LEGALE : *Via della costituente, 18 - 56024 Ponte a Egola (PI) - ITALY*  
SEDE OPERATIVA : *Via Sicilia - 56035 Perignano (PI) - ITALY - Tel. +39-0587-466722 Fax +39-0587-365138*  
C.F. e P.I. 01763650502 cap. soc. € 200.000,00 i.v.  
*http : [www.steelpumps.it](http://www.steelpumps.it)*